

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7254-0087:137 Page 1 of 1

**CATEGORY:** Heat Detector (Single/Multiple)

**LISTEE:** BRK, 3901 Liberty Street Rd., Aurora, IL 60504-8122  
Contact: Mark Dippner (630) 851-7330 ext 1422 FAX (630) 851-9309

**DESIGN:** Models HD6135FB single and multiple station, 120 VAC 9V DC, fixed temperature and rate of rise heat detector. The unit is designed to be used as an added source of information and should be used in conjunction with smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC, with 9V battery backup. 135<sup>0</sup>F fixed and 15<sup>0</sup>F/minute rate of rise.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as AC/DC powered, single and multiple station fixed and rate of rise temperature heat detector. The detector can also generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Units are acceptable for ceiling or wall mount. Refer to listee's Installation Instructions Manual for details.

09-28-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*