

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7263-0087:0510 Page 1 of 1

**CATEGORY:** 7263 -- SMOKE ALARM-COMBINATION SMOKE/CARBON MONOXIDE (PHOTOELECTRIC)

**LISTEE:** BRK BRANDS, INC. 3901 W. Liberty Street Road, Aurora, IL 60504-8122  
Contact: Daniel Eavenson (630) 499-3337  
Email: dan.eavenson@newellco.com

**DESIGN:** Model SC7010LBLV Single and multiple station photoelectric smoke and carbon monoxide alarm with a End-of-Life (EOL) feature that notifies the end user after the 10-Year life has expired. Refer to listee's Installation, Operation, and Maintenance Manual for detailed product description and operational considerations.

**RATING:** 120 VAC Standby battery 3Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes, NFPA 72, NFPA 720 and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or First Alert, model number, electrical rating, and ETL Mark.

**APPROVAL:** Listed as a combination single/multiple station photoelectric smoke and carbon monoxide alarm for indoor residential use. Refer to listee's Installation Instruction Manual for details.

**NOTE:** The photoelectric type alarms are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type alarms are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

09-26-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 02, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, M.E., F.P.E., Program Coordinator**  
*Fire Engineering Division*