



### AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the models described in the Products(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to the multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant: BRK BRANDS, INC.  
 3901 West Liberty Street Road  
 Aurora, IL 60504 USA

Contact Name: Mr. Mark Dippner Phone: (630) 851-7330

Manufacturer: Electronica BRK De Mexico SA de C V  
 Av. Fernando Borreguero Y Lopez Mateos  
 Parque Industrial Juarez  
 Cd. Juarez, Chihuahua, Mexico CP-32630

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Arlington Heights, IL USA

Report No.: 3078877CHI-002

Product Covered: First Alert and/or BRK Brands; Single and/or Multiple Station Smoke Alarms, 120Vac with battery backup and hardwired interconnect; Models 7010B, SA520, and SA520A. Model SA520 and SA520A have RF interconnect.

Description: The products have a primary line voltage supply with battery back-up. The units are Multiple-Station Smoke Alarms, may have a remote RF, and are intended to be wall or ceiling mounted.

Standard(s): Single and Multiple Station Smoke Alarms (ANSI/UL 217 – 5th Edition, rev. 01/2004) and Standard for Smoke Alarms (CAN/ULC-S531-02, October, 2002).

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by *for Michelle Lake*  
 \_\_\_\_\_  
 William T. Starr, Certification Manager

Date: February 12, 2007

Control Number: 3055574

This document supersedes all previous Authorizations to Mark for the noted Report Number.

Intertek Testing Services NA, Inc.  
 165 Main Street, Cortland, NY 13045  
 Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699