



AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the models described in the Products(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to the multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant: BRK BRANDS, INC.
3901 West Liberty Street Road
Aurora, IL 60504 USA

Contact: Name: Mr. Mark Dippner Phone: (630) 851-7330 x1422

Manufacturer: Electronica BRK De Mexico SA de C V
Av. Fernando Borreguero Y Lopez Mateos
Parque Industrial Juarez
Cd. Juarez, Chihuahua, Mexico CP-32630

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Arlington Heights, IL USA

Report No.: 3120637CHI-001

Product Covered: First Alert and/or BRK Brands: Single Station Battery Operated CO Alarm with Silence Feature, Model CO400.

Description: This product is intended to be wall mounted and powered by a primary battery only. The product is intended to detect an abnormal amount of carbon monoxide density in the area in which it is installed, and to actuate a condition specific audible alarm signal. The product has an alarm silence feature for convenience only and will not correct a CO problem. The unit is comprised of jumpers, capacitors, transistors, resistors, integrated circuits, a voltage regulator, a piezoelectric horn, a CO sensor, and general visual signaling LED. All components with the exception of the battery are mounted on a printed wiring board (PWB), and the assembly is then housed inside an enclosure having openings to the surrounding air. All alarms are intended to be installed in accordance with the User's manual and instruction sheets and the National Fire Alarm Code (NFPA 72).

Standard(s): Single and Multiple Station Carbon Monoxide Alarms (UL 2034, 2nd Edition, Revisions Through and Including March 8, 2005)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by: for Michelle Dale **Date:** August 29, 2007
William T. Starr, Certification Manager

Control Number: 3055574

This document supersedes all previous Authorizations to Mark for the noted Report number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
165 Main Street, Cortland, NY 13045
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699