

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7257-0087:0165 Page 1 of 1

CATEGORY: 7257 -- SMOKE ALARM-PHOTOELECTRIC TYPE (SINGLE/MULTIPLE)

LISTEE: BRK BRANDS, INC. 3901 W. Liberty Street Road, Aurora, IL 60504-8122
Contact: Mark Dippner (630) 851-7330 Ext: 3422 Fax (630) 851-9309
Email: Mdippner@jardensafety.com

DESIGN: Model P1000 single station battery operated photoelectric smoke alarm with silence feature. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3VDC Lithium battery: Duracell CR2 or EVE CR2

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or First Alert, model number, electrical rating, and ETL Mark.

APPROVAL: Listed as a single station battery operated photoelectric smoke alarm for indoor residential use only.

NOTE: The photoelectric type alarms are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type alarms are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

01-03-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **January 09, 2013**

Listing Expires **June 30, 2013**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division