

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7257-0087:0168

**CATEGORY:** Smoke Alarm-Photoelectric Type (Single/Multiple)

**LISTEE:** BRK BRANDS, INC., 3901 W. Liberty Street Road, Aurora, IL 60504-8122  
Contact: Mark Dippner (630) 851-7330 Ext: 3422 Fax (630) 851-9309  
Email: Mdippner@jardensafety.com

**DESIGN:** Models P910 and P910E single station photoelectric residential smoke alarm with silence feature. Models have a 10 yr. non-replaceable battery. Model 910E employs an "Escape" LED light. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 3 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes, NFPA 72, and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or First Alert, model number, electrical rating, and ETL Mark.

**APPROVAL:** Listed as a single station battery operated photoelectric smoke alarm for indoor residential use only. Refer to listee's Installation Instruction Manual for details.

**NOTE:** The photoelectric type alarms are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type alarms are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

08-13-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **August 21, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
Fire Engineering Division