



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b> BRK Brands, Inc.	<b>Manufacturer:</b> Electronica BRK De Mexico SA de C V Av.
<b>Address:</b> 3901 West Liberty Street Aurora, IL 60504	<b>Address:</b> Fernando Borreguero Y Lopez Mateos Parque Industrial Juarez Cd. Juarez, Chihuahua CP-32630
<b>Country:</b> USA	<b>Country:</b> Mexico
<b>Contact:</b> Mr. Mark Dippner	<b>Contact:</b> Martin Allande, Dolores Pita
<b>Phone:</b> (630) 851-7330 x3422	<b>Phone:</b> (915) 779-7800
<b>FAX:</b> (630) 851-9309	<b>FAX:</b> (915) 774-7804
<b>Email:</b> mdippner@jardensafety.com	<b>Email:</b> DPita@jardensafety.com

**Party Authorized To Apply Mark:** Same as Manufacturer  
**Report Issuing Office:** Chicago

**Control Number:** 3055574      **Authorized by:** \_\_\_\_\_  
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.


This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety for Single and Multiple Station Smoke Alarms (ANSI/UL 217 - 6th Edition, dated 08/25/06 with revisions through and including 11/20/12 - Includes 8/4/15 Future Effective Date requirements  Standard for Safety for Single and Multiple Station Carbon Monoxide Alarms (ANSI/UL 2034 – 3rd Edition, dated 02/28/08 with revisions through and including 02/20/09 and future effective date 02/20/15)
<b>Product:</b>	AC/DC (hard-wired, multiple-station) and DC only (battery operated, single-station) Ionization type
<b>Brand Name:</b>	First Alert and/or BRK Brands, Inc.
<b>Models:</b>	SC9120B, SCO2
<b>This document does not imply product certification nor authorization to apply the ETL-Listed Mark and should be submitted along with a valid Authorization to Mark from Intertek.</b>	
<b>Intertek Report Number:</b>	3187569CHI-002

Intertek Issuing Office:	Chicago
CSFM BML Category:	7256 - Ionization Smoke Detector (Single/Multiple) 5276 - Single/Multi Carbon Monoxide Detectors
Applicant/Listee:	BRK Brands, Inc.
Standards Used:	Standard for Safety for Single and Multiple Station Smoke Alarms (ANSI/UL 217 - 6th Edition, dated 08/25/06 with revisions through and including 11/20/12 - Includes 8/4/15 Future Effective Date requirements  Standard for Safety for Single and Multiple Station Carbon Monoxide Alarms (ANSI/UL 2034 – 3rd Edition, dated 02/28/08 with revisions through and including 02/20/09 and future effective date 02/20/15)
Product Covered:	AC/DC (hard-wired, multiple-station) and DC only (battery operated, single-station) Ionization type Residential Smoke and CO Alarm
Design	The product covered by this report is a Single and/or Multiple Station Ionization type Residential Smoke and Carbon Monoxide Alarm. It uses an electrochemical CO sensor for the detection of CO and an ionized sensing element for the detection of smoke. It is intended for indoor residential use only. All alarms are intended to be installed in accordance with the user's manual, instruction sheets, NFPA 72, NFPA 720, and all local codes.

Engineer



Kevin Sein  
Ass. Engineer, Chicago  
December 03, 2014

Reviewer

Rich Hoffman  
Staff Engineer  
December 03, 2014

Product inquiries should be made to Larry Todd, Intertek Chief Electrical Engineer at (503) 626-6694.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results in referenced from this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.