

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 5276-0087:0155

**CATEGORY:** 5276 -- CARBON MONOXIDE ALARMS

**LISTEE:** BRK BRANDS, INC.3901 W. Liberty Street Road, Aurora,, IL 60504-8122  
Contact: Mark Dippner (630) 851-7330 Ext: 1422 Fax (630) 851-9309  
Email: Mdippner@jardensafety.com

**DESIGN:** Models "First Alert" CO604 and CO614 single station, AC powered with battery back up Carbon Monoxide alarms. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC, 9 VDC battery

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or "First Alert" , model number, electrical rating and ETL label.

**APPROVAL:** Listed as Carbon Monoxide alarms for residential applications.

**NOTE:** Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

11-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **December 09, 2010**

*Listing Expires* **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*