

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-0087:0170

Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: BRK BRANDS, INC. 3901 W. Liberty Street Road, Aurora, IL 60504-8122
Contact: Mark Dippner (630) 851-7330 Ext: 3422 Fax (630) 851-9309
Email: Mdippner@jardensafety.com

DESIGN: Models CO910 and CO910V Single-Station Residential Carbon Monoxide Alarms with silence feature. The CO910V and the CO910 models are similar except the CO910V is equipped with Voice Notification. The Carbon Monoxide Alarm employs Electrochemical Carbon Monoxide Sensor for the detection of Carbon Monoxide. It is intended for indoor residential use only. The product uses a 10 year nonreplaceable lithium battery. The product also uses a feature that disables the unit from being installed after the 10 year life has expired. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3V Lithium Battery, Provisional EVE model CR17335

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name and/or First Alert, model number, electrical rating, and ETL label.

APPROVAL: Listed as Carbon Monoxide alarms for indoor residential applications. Refer to listee's Installation Instruction Manual for details.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

10-24-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 29, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division